


Plan Cheie:



Tr. S3 - S4; Q = 479.61mc/h  
L = 424m; DN 90mm;

S12

LEGENDA

CONDUCTA DE DISTRIBUTIE  
DE GAZE NATURALE PROIECTATA  
IN MONTAJ SUBTERAN DIN  
PEHD 100 SDR 11, SR ISO 4437

SPV 4 - Subtraversare curs de Apa  
in tub de protectie DN 114x4 L = 8ml

Tr. S2 - S12; Q = 145.28mc/h  
L = 464m; DN 63mm;

Verificator			A4, B2, D2		
Expert			A4, B2, D		
Verificator/ Expert	Nume:	Semnatura:	Cerinta	Referat / Expertiza nr./Data	
PROIECTANT: SC COLUMN CONSULT SRL BISTRITA Str. Taberei, nr. 5A, tel: 0756/144784 J06/554/2008, CUI R023967516			Denumire Lucrare: ALIMENTARE CU GAZE NATURALE LOCALITATEA COMPONENTA SLATINITA, MUNICIPIUL BISTRITA, JUDETUL BISTRITA-NASAUD	Plansa PS.17	
			Beneficiar: MUNICIPIUL BISTRITA JUDETUL BISTRITA-NASAUD	Proiect 7G/2021	
				SF	
	Nume	Semnatura	scara	data	Titlu Plansa:  PLAN DE SITUATIE RETEA ALIMENTARE GAZ LOCALITATEA SLATINITA
Sef proiect	ing.Muresan Ioan		1:2000	2021	
Proiectat	ing.Muresan Ioan				
Desenat	ing.Muresan Ionut				